



UL1994-listed by Underwriters Laboratories: Photoluminescent Egress Path Marking System Component	Handrail Marking, Wall-mounted Perimeter Demarcation Line, Door Frame Marking, Push Bar Marking Item-Nos.: 82-40709 + 82-40709L
---	---

Item-No:	Description:	Dimensions:
82-40709 82-40709L	<p>Used to mark:</p> <ul style="list-style-type: none"> • Handrails and handrail extensions with a solid and continuous stripe on the top surface of handrails for their entire length, including extensions and newel post caps. Where handrails or extensions bend or turn corners, the stripe shall not have a gap of more than 4 inches. See 2009 IBC Sec. 1024.2.3 • Wall-mounted Perimeter Demarcation Line, placed on the wall with the bottom edge of the stripe no more than 4 inches (102 mm) above the finished floor. See 2009 IBC Sec. 1024.2.4.2 • Panic Bars of doors from exit enclosures on entire length of the actuating bar or touchpad. See 2009 IBC Sec. 1024.2.6.2 • Door Frames of Doors from exit enclosures through which occupants within an exit enclosure must pass to complete their exit path. See 2009 IBC Sec. 1024.2.6.3 <p>Polyester Thin Film, approx. 0.008-inch = 8 mil film thickness plus adhesive-protecting paper liner = Total approx. 0.015-inch = 15 mil Film/ Adhesive/ Liner combined. Photoluminescent strontium-aluminate pigment inside film surface.</p> <p>2-inch x 82 feet per Roll: all-photoluminescent</p> <p>2-inch x 164 feet per Roll: all-photoluminescent</p> <div style="text-align: center;">  <p>UL Model-Number: CC-TAPE</p> </div>	<p style="text-align: center;">2-inch x 82 foot Roll</p> <div style="text-align: center;">  </div> <p style="text-align: center;">2-inch x 164 foot Roll</p>

Typical Use
<p>Photoluminescent Egress Path Marking Component</p> <ul style="list-style-type: none"> ✓ In compliance with IBC Section 1024 'Luminous Egress Path Markings' ✓ In compliance with NFPA 101-<i>Life Safety Code</i> Section 7.2.2.5.5 'Exit Stair Path Markings' ✓ For NYC Local Law 141 compliance: this needs specific NYC Labeling: contact us!! ✓ UL1994-listed by Underwriters Laboratories, Inc. to 'Standard for Luminous Egress Path Marking Systems' as Model: CC-TAPE All-Photoluminescent UL1994-Listing obtained at half-inch (= 1/2") strip width !! ✓ Activation by LED and Fluorescent lighting <p>All-Photoluminescent ideal as</p> <ul style="list-style-type: none"> • Handrail Marking • Wall-mounted Perimeter Demarcation Line with the bottom edge no more than 4-in. above the finished floor • Door Frame Marking on doors through which occupants must pass to complete their exit path • Push Bar marking on those doors